



CITY OF LAS VEGAS  
DEPARTMENT OF BUILDING & SAFETY  
PERMIT APPLICATION

Project # 266962-614 (CLV ONLY) Parent (Original) Project # \_\_\_\_\_

FOR: ☒ Commercial & Public Structures ☐ Single Family Residence VALUATION: \$ 3,122.00

WORK DESCRIPTION: Relocate electrical service for ADA lift access

\*Please use the Web Estimator, <http://www.lasvegasnevada.gov/Apply/permitEstimator.htm>, for your fee estimates. A print out of your Permit Estimator results should be attached to this application. Do not bring a pre-printed check as your final fees may be different from the estimate.

PROJECT/TENANT NAME: The Mob Museum

PROJECT ADDRESS: 300 Stewart Ave. ZIP 89101

PARCEL NO.: 139-34-501-007 ZONE: \_\_\_\_\_ Land Use/Entitlements: \_\_\_\_\_

APPLICANT INFORMATION:

Company Name: Pacific Electric, Inc. Individual Name: Gary Sweeney

Phone: 702-433-8777 Fax: 702-433-1785 Email: gary@pacificelectriclv.com

CONTRACTOR INFORMATION:

☐ Owner/Builder (Residential Only on primary residence)

Company Name: Pacific Electric, Inc. Individual Name: Gary Sweeney

Phone: 702-433-8777 Fax: 702-433-1785 Email: gary@pacificelectriclv.com

State Contractor License: 0023856 City of Las Vegas Business License: 3000000243

REQUIRED FOR SUBMITTAL: (Please note that plan check fees are based on occupancy, use, construction type and square footage)

OCCUPANCY GROUP: \_\_\_\_\_ USE: \_\_\_\_\_ CONST. TYPE: \_\_\_\_\_

TOTAL SQUARE FOOTAGE: \_\_\_\_\_ AFFECTED SQ' (TI's): \_\_\_\_\_ ☐ Is this a Highrise? More than 55'?

**\*\*IF THE BUILDING IS MIXED USE, PROVIDE CODE ANALYSIS PER FLOOR AS A SEPARATE ATTACHMENT\*\***

SQUARE FT OF FLOOR AREAS: 1<sup>st</sup> \_\_\_\_\_ 2<sup>nd</sup> \_\_\_\_\_ 3<sup>rd</sup> \_\_\_\_\_ Garage \_\_\_\_\_

Patio \_\_\_\_\_ Balcony \_\_\_\_\_ No. of Units \_\_\_\_\_ No. of Stories \_\_\_\_\_

SPECIAL CONDITIONS: \_\_\_\_\_

I state that the information I have supplied on this application is true and correct. By signing this application, I agree to comply with all conditions as noted on this permit.

[Signature] 8/12/14  
Contractor or Agent / Owner Date

Planning Department Date

Land Development Floor Control Engr. Date

Fire Department Date

[Signature] 8/13/14  
Building Department Date

TOTAL PERMIT FEE: \$ PAID

PRE-PAID: Plan Review \$ \_\_\_\_\_

PRE-PAID: Zoning \$ \_\_\_\_\_

TOTAL \$ \_\_\_\_\_

**Permit Expires 180 Days After  
Abandonment of Work**

Permits expire when no inspection has been approved for any 180-day period after the permit has been issued.

**PACIFIC ELECTRIC**

266962 C 14


License #23856

August 13, 2014

City of Las Vegas  
Development Services Center

Please allow Oscar Corona, employee of Pacific Electric to pick up approved plans and permit.


Thank You,



Dayna Sprague  
Construction Secretary

**City of Las Vegas**

LasVegasNevada.gov

*Serving You Online Rather Than In Line*View: [Pay Fees](#) | [View Inspections](#) | [Schedule Inspection](#)[ (1) [Clear Permit List](#) ] [ (0) Item(s) in your shopping cart ] [ [Log Off](#) ]

## Payment Receipt

Date of Transaction: 8/13/2014 7:50:16 AM  
Transaction Status: Approved  
Receipt ID: 199695-01  
Key: 507816, AP# 266962

ADMIN	\$54.00
MISC APPARATUS/CONDUITS/AND CONDUCTORS	\$173.00
PLAN CHECK COUNTER REVIEW	\$80.00

Total Posted: \$307.00

Please print a copy of this receipt for your records.

[Print...](#)[Return to Inspections](#)

Questions? [Contact Us](#)

**PACIFIC ELECTRIC**

License #23856  
 BID LIMIT 1,000,000.00

THE MOB MUSEUM  
 300 E. STEWART  
 (NO SCALE)

**CLV****RECEIVED**

AUG 12 2014 266962

**CITY OF LAS VEGAS**

NEW LIFT  
 EQUIPMENT  
 LOCATION

EXISTING  
 ADA LIFT

EXISTING LIFT  
 EQUIPMENT  
 LOCATION

**Project Description:**

Relocate the ADA lift service & equipment to an indoor space to eliminate heat related breakdowns. The electrical work and hook-up will be performed by Pacific Electric, the lift equipment will be provided and installed by others.

New lift equipment electrical requirements: 20 amp 120 volt circuit with disconnect switch  
 Source: Panel EBLR, circuit # 29, in existing conduit.

**PLANS APPROVED  
 ELECTRICAL**  
 Building & Safety Dept.  
 City of Las Vegas, Nevada

EDS AUG 12 2014

Does Not Include Structural, Architectural,  
 Plumbing/Mechanical or Off-Site  
 Improvements. Make No Change  
 Without Approval. Plan is  
 Not a Permit to Violate Any Ordinance.

Pacific Electric

*Jean-Guy Gaumond*  
 Jean-Guy Gaumond  
 Master License #1355